

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE OF PAGES 1   2	
2. MODIFICATION NO.:  0003		3. EFFECTIVE DATE  AUG 23, 2002		4. REQUISITION/PURCHASE REQ. NO.  W81W3G-2035-7181		PROJECT NO. (If applicable)	
6. ISSUED BY Department of the Army Baltimore District, Corps of Engineers Contracting Division P.O. Box 1715 Baltimore MD 21203-1715		CODE	CA31	7. ADMINISTERED BY: Contracting Division, Contracts Branch CENAB-CT-C 10 S. Howard ST. Room 7000 Baltimore, MD 21203-1715		CODE	E1P0100
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(x)	9A. AMENDMENT OF SOLICITATION NO.  DACA31-02-R-0011		
				X	9B. DATED (SEE ITEM 11) JUL 29, 2002		
					10A. MODIFICATION OF CONTRACT/ ORDER NO.		
					10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE					

## DESIGN-BUILD 55<sup>TH</sup> COMBAT CAMERA OPERATIONS FACILITY FORT MEADE, MARYLAND

**SEE THE FOLLOWING PAGE**

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ (signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	

AMENDMENT NO. 0003 TO ADVERTISED RFP DACA31-02-R-0011  
EFFECTIVE AUG 23, 2002

AMENDMENTS:

1) Amendment 0001, Item 3, Section 01011, Chapter 2: Add the following to the end of paragraph 2.10.1.11: “Fire hydrants shall be equipped with 1 – 4.5in and 2 – 2.5in. outlets with National Standard thread.”

DRAWINGS:

2) Sheets C1 and C2, Site Plan: To the symbol approximately 60ft south of northern project “LIMITS OF SITE” line, consisting of the capital letters “SB” within a box, add a note reading “Underground splice box with above ground bollards at each of the four corners. The location of this splice box is conceptual only and will be adjusted in final design to accommodate and not conflict with any proposed site pavement for the new 55<sup>th</sup> Combat Camera Operations Facility. There is a possibility this splice box may not be located at the project site.”